

INDRAPRASTHA INSTITUTE OF INFORMATION TECHNOLOGY, DELHI (IIITD)
Okhla Industrial Estate, Phase III
New Delhi 110020
(Tel No 011-26907400, Website: www.iiitd.ac.in)

Dated : 18.12.2017

SITC OF ENERGY METERS IN ELECTRICAL PANEL
FOR PHASE II CONSTRUCTION OF
INDRAPRASTHA INSTITUTE OF INFORMATION TECHNOLOGY DELHI AT OKHLA-III,
DELHI
ADDENDUM-1

S.NO	CONTRACTOR'S QUERIES (TENDER CLAUSE)	REPLY
1.	Item No. 1. The burden, accuracy, ID or Bus bar size of CT, VA Burden and Class of CT in order to proceed further.	Burden should not matter. Accuracy - Class 1 (or 1%) Bus-bar size - All the CTs will be around regular wires/cables.
2	Item No. 6: Supply and fixing of meter box for Two & Four Meter. The complete nomenclature of meter box has not been mentioned such as Metal, size, gauge, drawing etc. not provided.	Each meter is standard 96mmx96mm Supply, installation, testing & commissioning of cubicle type totally enclosed free standing type / wall Mounted type moisture, dust and vermin proof Meter Board made out of 1.63 mm CRCA sheet steel complete with terminal block , gland etc, as per requirement. Size of Box : For Two Meter : 200mm x 350mm x 150mm For Four Meter : 500mm x 300mm x 150mm

LIST OF APPROVED MAKES FOR ABOVE SAID WORKS

Energy Meter	Schneider, Enersol, ElMeasure, L&T (with Class 1.0 accuracy)
MCB's,	Legrand / L&T / Havells
Data Cable	Havells/Polycab/Finolex/KEI
PVC Conduit	AkG/BEC/ Polypack
Current Transformer	AE/Kappa/NewTek Electricals/ Trinity

For 2 Meter



For 4 Meter

