

TENDER BID FOR SOLAR HOT WATER SYSTEM

EXTENSION OF LAST DATE OF SUBMISSION OF COMPLETE BID DOCUMENTS:

LAST DATE OF SUBMISSION OF DOCUMENTS EXTENDED TO 24 /10/2011 at 3 PM and
OPENING ON 25/10/2011 at 11A.M.

CLARIFICATIONS ON PREQUALIFICATION CUM TENDER BID FOR SOLAR HOT WATER SYSTEM

This is to clarify the following:

1. We have asked for both types of panels – flat plate and evacuated tube . You may bid for both alternates.
2. The bidder shall mount the collectors on a framework so as to allow a working height of 2.1 m clear below it at all points, with a design whetted by the architects. At this time we need you to clarify your structural steel rate and the quantity assumed to be required.