

Replies to the Queries for Expression of Interest, Data Centre

Para or Clause No	Heading Details	Present Clause	Query by bidders	Response By IIITD
Page No-3, point no :3	Eligibility/Qualification criteria, S.No-5	The bidder must have successfully executed establishment of three Tier3 Data Centre with at least one TIER III certified DC in India. The single similar order value should 1.2 Cr each Or Two similar works of Rs 0.9 Crs each Or Three similar works of Rs 0.24 Crs each in any one of last five financial years ending Feb2020 *	We request you to please amend it as "The bidder must have successfully executed establishment of three Tier-3 Data Centre with at least one TIER III/Rated 3 certified DC or TIER III/Rated 3 complied DC in India. The single similar order value should 1.2 Cr each Or Two similar works of Rs 0.9 Crs each Or Three similar works of Rs 0.24 Crs each in any one of last five finanacial years ending Feb 2020*" AND The bidder must have successfully executed establishment of three Data Center with Tier III or Rated 3 with at least one from Uptime (TIER III) DC, One EPI (Rated 3). The singe similar order value should be not less than 1.2 Cr each. AND Very few data centers in India are TIERIII Certified and also	IIITD will accept bids from bidders who successfully executed establishment of three Tier-3 Data Centre with at least one TIER III/Rated 3 certified DC or ANSI/TIA-942 Tier-3 or TIER III complied DC in India. The single similar order value should 1.2 Cr each Or Two similar works of Rs 0.9 Crs each Or Three similar works of Rs 0.24 Crs each in any one of last five financial years ending Feb2020 * Corrigendum for same will be published on institute's website https://www.iiitd.ac.in/tenders

			only MNC's have delivered such certified data centers. So this clause will restrict to SME's from entering in this bid You are requested to remove this clause to allow SME's also	
Page No-3, point no :3	Eligibility/Qualification criteria, S.No-6	Bidder should be in the business of DEVELOPMENT OF datacenter for last 5 years	We request you to please amend it as Bidder should be in the business of DEVELOPMENT OF datacenter for last 7- 10 years	Bidder should be in the business of DEVELOPMENT OF Datacenter for last 7 years. Corrigendum for same will be published on institute's website https://www.iiitd.ac.in/tenders
Page No-3, point no :3	Eligibility/Qualification criteria, S.No-10	The bidder should have an experience in providing onsite support for DC operations and DC management services.	We request you to please amend it as "The bidder should have an experience in providing onsite support for minimum 25 DC operations and DC management services.	No Changes.
Page No-3, point no :3	Eligibility/Qualification criteria, S.No-12	The bidder must have on its roll adequate number of technically qualified professionals in systems integration, product installation, commissioning and related services out of which 2 should have certified as Data centre professional (CDCP), 2 CDCS, 2 Electrical consultants for designing the Electrical system, 2 Mechanical consultants for designing the HVAC and other systems.	The bidder must have on its roll adequate number of technically qualified professionals in systems integration, product installation, commissioning and related services out of which 2 should have certified as Data centre professional CDCP- 2, CDCS-2, ATD-2 Nos Electrical consultants for designing the Electrical system,2 Mechanical consultants for designing the HVAC and other systems. And	The bidder must have on its roll adequate number of technically qualified professionals in systems integration, product installation, commissioning and related services out of which 2 should have certified as Data centre professional (CDCP)/2 CDCS,2 Electrical consultants for designing the Electrical system,2 Mechanical consultants for designing the HVAC and other systems.

Page No-6, point no :4	Evaluation criteria	Tentative makes/models (1 or more) of equipment such as DG, UPS, chillers,	We request you to please amend it The bidder must have on its roll adequate number of technically qualified professionals in systems integration, product installation, commissioning and related services out of which 2 should have certified as Data centre professional (CDCP)/2 CDCS,2 Electrical consultants for designing the Electrical system,2 Mechanical consultants for designing the HVAC and other systems. DG is not part of scope of work in RFP so please clarify that Is DG in vendor's scope or	Corrigendum for same will be published on institute's website https://www.iiitd.ac.in/tenders Installation of DG is not in bidder's scope of work. IIITD already has DG
Page No-10, point no :10	HVAC sub point 1	cooling tower, PAC, racks etc. The HVAC systems for both the data centres should have N+1 redundancy	not. As per RFP there is only one Data Center to consider then word "both the data centers" conflicts here. Please clarify.	installed. There is only one datacenter this should be interpreted as: "The HVAC systems for the data centre should have N+1 redundancy" Corrigendum for same will be published on institute's website https://www.iiitd.ac.in/tenders