

REPLIES TO QUERIES Tender No. 02/2019 HVAC WORKS FOR INCUBATION CENTRE		
S.No. of item as per BOQ	QUERY DESCRIPTION	REPLY
1	The snap acting thermostat may be omitted as it was not included in the previous contract (TENDER NO: 5/2018 Dated 23.5.2018 of incubation Centre).	The provision of snap acting thermostat stand deleted from item No-1.
1	Danfoss and Honeywell make may be included in the list of approved makes.	Danfoss and Honeywell make Included in the list of approved makes. For 2 way motorized valve in addition to : Anergy/Siemens/Frese
3	Edgetech and Flowel make may be included in the list of approved makes.	Edgetech and Flowel make Included in the list of approved makes. For Fan coil unit in addition to : Bhaturia/Caryaire/Carrier/Midea
7	HRV i.e Heat Reclaim Ventilation. The description of this item should be corrected by deleting ' Descant absorption material' as it is not HRW (Heat Recovery Wheel).	"desiccant absorption material non contact seal" to be replaced by "plate type aluminium heat exchanger" for HRV.
11, 13 and 15	Flowel make may be included in the list of approved makes.	Flowel make Included in the list of approved makes at item no 11 , 13 and 15
NIT	EMD - Cos registered with MSME requested for exemption of EMD	Those registered under MSME may not necessarily submit EMD. However, a valid certificate issued by Govt. of India in this regard must be enclosed failing which tender will not be considered.