

CLARIFICATION

Ref : Notice Inviting Quotation No IIIT-D
/BldgProj/M&C/73/2010 dated 16th Nov2010.

SCOPE OF WORK ,TERMS AND CONDITIONS

Clause 12

The quantity of stone broken down to sizes against item 1(a)size 90 to 65mm,(b)60to 45mm,and (c) 53to 22.4mm shall be measured in stacks of sizes as directed and reduced by 7.5% towards voids .

The quantity of stone broken down to sizes against item 1(d) 230 to 300mm shall be measured in stacks of sizes as directed and reduced by 15% towards voids .