

**Dated : 10.07.2019**

TENDER NO: 6/2019 Dated 4/7/2019

**REPLIES TO QUERIES -II ON NIT FOR COMPUTATIONAL BIOLOGY WET LAB FURNITURE WORKS**

S.NO	DESCRIPTION (AS PER TENDER)	TENDER DOC PAGE NO.	PRE-BID QUERIES	REPLIES
1	EMD:- Rs. 60,000/-	3	We would like to inform you that we are registered with NSIC and we get all the special benefits granted to the firms registered under NSIC in govt. tenders across India. We are furnishing with this a copy of our NSIC registration certificate for your reference. Kindly go through it and confirm us for the exemption of EMD.	Yes Exempt.
2	BIFMA Certificate	9	As the scope contains metallic furniture BIFMA certificate is not relevant to metallic furniture	Not mandatory.
3	Copy of Certificate of Registration in case of registration with CPWD / MES / Railways / P&T / AIR / State PWD etc.	10	We request you to remove the same clause	Not mandatory.
4	Table-C1 , C2 ,C3	19-24	Please Simplify the format of similar works and kindly remove the clauses of loose furniture and fixed furniture as it is indeed difficult to bifurcate the same.	Loose and fixed furniture not to be bifurcated.
5	Make of Water tap, bench Mounted valves, Spot Extractors , safety Shower	66	Kindly include premier polymer make for the said items.List provided.	No change from tender conditions
6	Make of Exhaust fan	66	We request you to consider Indian reputed make for said item. List provided	No change from tender conditions
7	Submission of Tender Date of hardcopy submission : 12.07.2019 up to 3.00 p.m	66	We would like to apprise you that due to short time period we have got for preparing the tender bid after the receipt of Pre-bid reply, we request you to kindly grant us the extension to submit the tender bid for another 15 days. We ensure to submit our tender bid before this date.	Last date of submission extended by 7 days from date of release of prebid replies ie by 17/07/2019 upto 3:00PM .
8			For fumehood EN and ASHRAE STANDARD COMPLIANT has been asked. We request you to kindly consider submission product certification documents against quoted tender. In case of not sharing the EN 14175 and ASHRAE STANDARD COMPLIANT PRODUCT certification the bidder shall be disqualify to consider the design standard certification.	EN and ASHRAE compliance certificate is to be provided as part of PQ documents

S.NO	DESCRIPTION (AS PER TENDER)	TENDER DOC PAGE NO.	PRE-BID QUERIES	REPLIES
9			For Fumehood NEPA-45, ASTM D552, UL, NIH03-112C, NSF STD#49 has mentioned in tender which is not related to any lab fumehood. We request you to kindly delete these certificate requirement.	These are not mandatory.
10			For lab bench NFPA 30, NFPA-45,UL, ASTM D552 has mentioned in tender which is not related to lab bench. We request you to kindly delete these certificate requirement. For bench <b>SEFA 10/8M</b> is the best certification for checking the quality and strength of product in reference to discussion held with you in pre bid meeting.	SEFA 10/8M is mandatory.
11	APPLICABLE CODES & STANDARDS:	No 79	NSF STD#49 - Photometric Method of Testing NIH03-112C - National Institute of Health Specification UL - Underwriters Laboratories ASTM D552 - Bending Test NFPA-45 - National Fire Protection Association We request you to waive off this codes and standards as these are not relevant to Laboratory Furniture and Fume Hoods.	These are not mandatory.
12			Pls let us know if IIIT is allowed concessional 5% gst against a DSIR certificate. We need to submit an offer for your labs, hence require this info.	GST Concessional certificate not applicable for furniture procurement purpose.
13	ALL BOQ ITEMS		Civil ,Electrical and plumbing works are included or not	All Civil ,Electrical and plumbing works are included in the scope. Single point water supply and drain outlet will be provided . Rest of works to be carried out by vendor. Electricity distribution points are available in wall /floor. These can be seen during site inspection . Civil cutting in shaft/wall & making good, scaffolding in shaft, foundation works in terrace are included.Embedding crossing pipes in wall and floor included in scope of vendor.