

Tender No: 1/2019

| REPLIES TO QUERIES ON INTERIORS (INCLUDING ELECTRICALS) WORKS FOR INCUBATION CENTRE | | |
|---|--|---|
| DURING PRE-BID MEETING HELD ON 1/7/2019 | | |
| S NO | PRE-BID QUERRIES | REPLIES |
| 1 | Use of calcium silicate board was suggested in place of gypsum board in partitions | No change in specifications . Double layer of 12.5mm gypsum board to be used on each side skin of the partition as per tender item . |
| 2 | ESI & PF to be paid by Contractor | Yes . ESI & PF are to be paid by the Contractor and rates are inclusive of the same. No extra reimbursement will be made on any such account. |
| 3 | Estimates are inclusive of GST | Yes , estimated cost as indicated is inclusive of GST. |
| 4 | Issue of working in an operational area | Materials to be carted by the stairs , Scrap/ debris to be disposed away from campus as per norms. |